Middle Level Commissioners

Water Resources

Abstraction Level Parameters

Approximate Scale

MLC Datum		
	99.65	St Germans Pond – Maximum Summer Water Retention Level
	99.58	Bevills Leam Pond - Maximum Summer Water Retention Level
-	99.57	and falling. Send text message to IDBs stating voluntary closure of slackers is imminent unless an improvement in MLC levels is apparent
	99.55	Voluntary closure of slackers text message to IDBs Speak to EA consider bringing in 4 nights irrigation (Andy Chapman)
	99.52	Trigger point for 4 night irrigation (Mon, Tues, Thurs, Fri nights) IDB slackers to remain closed until level bounces back to 99.52-53 then try text message to only take minimum requirements through IDB slackers
	99.45	Cessation level. All IDB inlets/slackers must be closed immediately